



STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

Janet T. Mills  
GOVERNOR

Bruce A. Van Note  
COMMISSIONER

September 10, 2020  
Subject: Taylor Brook Bridge Replacement  
State WIN: 022224.00  
Location: **Auburn**  
**Amendment No. 2**

Dear Sir/Ms.:

The following question has been received:

**Question:** Please confirm that the reinforcing material for the Precast NEXT Beams is PLAIN, ASTM A 615, GRADE 60. Including the stirrups that are to project into the CIP deck of the superstructure.

**Response:** All mild steel reinforcing in the NEXT beams, including the stirrups projecting into the CIP deck of the superstructure, shall be plain reinforcing steel meeting the requirements of ASTM A 615, GRADE 60.

Consider this information prior to submitting your bid on **September 16, 2020**.

Sincerely,

A handwritten signature in blue ink that reads "George Macdougall".

George M. A. Macdougall P.E.  
Contracts & Specifications Engineer