



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

May 6, 2022
Subject: East Hastings Bridge Replacement
State WIN: 022252.00
Location: **Merrill**
Amendment No. 1

Dear Sir/Ms.:

The following questions have been received:

Question: I was inquiring to see if there is a cad file for the East Hastings Bridge replacement project in Merrill that can be had by prospective bidders?

Response: The Department will publish design CADD files for informational purposes. Any use of this information is subject to Standard Specifications Section 105.6.2.2.

Question: Can you please confirm that all reinforcing steel in the precast slabs is to be plain ASTM A615, grade 60 and not GFRP?

Response: All reinforcing in the precast slabs shall be plain steel meeting ASTM A615, grade 60.

Consider these changes and information prior to submitting your bid on **May 18, 2022**.

Sincerely,

A handwritten signature in blue ink that reads "George Macdougall".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer