STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

May 9, 2023
Subject: Mattagodus Bridge Replacement
State WIN: 022266.00
Location: Webster Plantation
Amendment No. 3

Dear Sir/Ms.:

The following questions have been received:

Question: Note 22 on sheet 2 of 30 states that the existing abutments will be removed in their entirety. The existing plans state that the existing footings go to ledge. At existing Abutment #1, ledge is estimated to be around elevation 298 ft which is 10 feet below the bottom of rip rap. Does MaineDOT anticipate that existing abutment #1 goes down to ledge? Can Abutment #1 be removed to 1 ft below bottom of rip rap (elevation 308 ft)? What are the removal limits for abutment 2 demo?

Response: Both abutments shall be removed in their entirety.

.

Consider these changes and information prior to submitting your bid on **May 10, 2023**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer