



Janet T. Mills
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Bruce A. Van Note
COMMISSIONER

April 12, 2019
Subject: Culvert Replacement
State WIN: 022297.00
Location: **Pittston**
Amendment No. 3

Dear Sir/Ms.:

The following question has been received:

Question: There is a 10" gas line and water main running through the project. Are the elevations of these items known? The concern is possible conflicting elevations with the new culvert.

Response: The water main is approximately 5 feet below grade, and the gas line invert is approximately 4 feet below grade.

Consider these changes and information prior to submitting your bid on **April 17, 2019**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer