



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

March 16, 2022
Subject: Bridge Replacements & Highway
Intersection Reconstruction
State WINs: 022511.01, 022512.01
& 022950.01
Location: **Old Town**
Amendment No. 2

Dear Sir/Ms.:

The following questions have been received:

Question: Detail "typical abutment section @ Sewer" on sheet C-5 of the Wright-Pierce drawings states a 16" sch 40 galvanized steel casing pipe to be used. The carrier pipe O.D. is 12.43, this does not allow enough room for casing spacers and end seals to be installed per the manufacturer. A minimum 18" casing pipe would be required and due to supply issues with 18" they recommended a 20" casing pipe. Please let me know how you would like us to proceed.

Response: The diameter of the galvanized steel schedule 40 casing pipe for the sewer line through the abutments shall be changed from 16 inch to 20 inch. To avoid conflicts with the approach slabs, the approach slab seat shall be shifted up 2 inches.

Updated approach slab seat elevation:

Bridge #1, Abutment #1 – $105.38' + 0.17' = 105.55'$

Bridge #1, Abutment #2 – $106.41' + 0.17' = 106.58'$

Bridge #2, Abutment #1 – $107.61' + 0.17' = 107.78'$

Bridge #2, Abutment #2 – $109.86' + 0.17' = 110.03'$

Question: Sheet C102 states costs for temporary water connection and fittings for temporary water main on temporary bridge will be paid for under bid item 830.50, we cannot find bid Item 830.50, please clarify.

Response: The temporary water main on the temporary bridge is paid for under item 825.5411 Temporary Water Main. On Sheet C102, please revise the pay item from 830.50 to item 825.5411, make this change in pen and ink.

Question: The bid book for this project states that a Material Transfer Vehicle will be paid for under Bid Item 403.40. The bid form does not contain this Bid Item, please advise.

Response: For this contract, the Material Transfer Vehicle is an option for the Contractor. If they choose the option, we will add the 403.40 item via a contract modification.

Consider these changes and information prior to submitting your bid on **March 30, 2022**.

Sincerely,



George M. A. Macdougall P.E.
Contracts & Specifications Engineer