



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

February 6, 2024

Subject: Precast Concrete Box
State WIN: 022835.10
Location: **Brighton Plantation
Amendment No. 1**

Dear Sir/Ms.:

The following questions have been received:

Question: Can you please provide the cover we are to design to? We could make some assumptions and measure off the print, but the drawings are "Not To Scale"

Response: The depth of cover will be approximately 3.5 feet.

Consider these changes and information prior to submitting your bid on **February 14, 2024**.

Sincerely,

A handwritten signature in blue ink that reads "George Macdougall".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer