



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

November 30, 2018
Subject: Culvert Replacements
State WIN: 022896.00
Location: **Mount Vernon**
Amendment No. 2

Dear Sir/Ms.:

The following question has been received:

Question: 603.400 states 81-inch by 59-inch rise pipe arch. Special provision does not state pipe type. The special provision references pipe ties. What type of pipe does the Department want?

Response: The pipe shall be Polymer-Precoated Galvanized Corrugated Steel Pipe.

Consider these changes and information prior to submitting your bid on **December 5, 2018**.

Sincerely,

A handwritten signature in black ink that reads "George M. A. Macdougall" followed by the initials "TBR".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER