



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

February 25, 2021
Subject: Large Culvert Replacement
State WIN: 023032.00
Location: **Whitefield**
Amendment No. 1

Dear Sir/Ms.:

The following question has been received:

Question: If the Contractor's "Means and Methods" require them to disturb more length of Route 194 to complete the installation of the new 10-foot diameter culvert then what is shown on the Contract Drawings will the additional work be paid for by the different contract items, or will it be incidental to Item 603.4078? We believe that due to the depth of the new culvert the development of the access to get the streambed material inside the new culvert and to access the equipment necessary to set the new culvert the 100' of full box cut and the two 25' transitions will not be enough room.

Response: As shown on the Plans the project limits along the road shall be Station 13+00 to Station 14+50. If additional road surface is disturbed because of the Contractor's "Means and Methods" all additional work would be incidental to all contract items.

Consider these changes and information prior to submitting your bid on **March 10, 2021**.

Sincerely,

A handwritten signature in blue ink that reads "George Macdougall".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer