STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

July 13, 2020
Subject: Bridge Work, Pavement Milling, Ultra-Thin Bonded Wearing Course with Safety Improvements
State WINs: 023617.50, 023617.60, 024119.00 & 024173.00
Location: **Carmel to Old Town**
Amendment No. 2

Dear Sir/Ms.:

The following question has been received:

Question: Is there a maximum depth of concrete repair that is incidental to the bridge joint type 3a and type 3b Items? Would we be paid for concrete repair under item # 518.51 after a specified depth?

Response: Bridge joint type 3a and 3b are intended for concrete header replacement only, no deck repair work is to be considered. Consider incidental to these items a maximum depth of concrete replacement to 1-inch below top mat of reinforcement. No additional payment will be made for deeper concrete removal.

Consider these changes and information prior to submitting your bid on **July 15, 2020**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer