



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

December 13, 2022
Subject: Tracy Brook Bridge
Replacement
State WIN: 023657.00
Location: **Durham**
Amendment No. 1

Dear Sir/Ms.:

In the bid book:

On page 14 "NOTICE TO CONTRACTORS" **CHANGE**, the bid opening date in the first paragraph from "December 28, " to read "**January 11, 2023**". Make this change in pen and ink.

The following questions have been received:

Question: Due to the holidays and companies being shutdown between Christmas/New Year's, would the Department please move the bid date to 1/11/2023?

Response: The Bid opening date will be Postponed to January 11, 2023

Question: Can you please confirm the type / finish on the rebar used for the reinforcing of the NEXT Beams (i.e. Black, Epoxy Coated, HDG, Low Carbon Chromium, etc....)?

Response: Mild reinforcing in the NEXT beams shall be plain carbon-steel bars (Black Bar).

Question: If Black, can you please confirm that Grade 706 (Weldable) rebar is an acceptable substitution for A615 rebar?

Response: ASTM A706 Grade 60 may be substituted for ASTM A615 reinforcing for mild reinforcing in the NEXT beams.

Consider these changes and information prior to submitting your bid on **January 11, 2023**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer