



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

June 5, 2025
Subject: UV Cured Pipe Liner
WIN: 023683.00
Location: **Mexico**
Amendment No. 1

Dear Sir/Ms.:

The following questions have been received:

Question: Please provide estimated catch basin depths.

Response: 4ft, 6ft and 10ft basins

Question: Maps appear to be missing for some of the Roxbury Rd lines. Please provide if available.

Response: See the attached maps


Consider these changes and information prior to submitting your bid on **June 11, 2025**.

Sincerely,

A handwritten signature in blue ink, reading 'George Macdougall'.

George M. A. Macdougall P.E.
Contracts & Specifications Engineer

ROXBURY RD BASINS



The Maine Department of Transportation provides this publication for information only. Reliance upon this information is at user risk. It is subject to revision and may be incomplete depending upon changing conditions. The Department assumes no liability if injuries or damages result from this information. This map is not intended to support emergency dispatch.

0.07 Miles
1 inch = 0.05 miles

Date: 6/4/2025
Time: 12:22:34 PM

LEGEND

Guardrail

— Not Route XY

— Route XY

● Drainage Outlets

■ Culverts - Large

Catch Basins

Network Type

● On System

● Off System

Bridges - All

Bridge Status

■ In-Service

⊗ Closed

■ Proposed

ROXBURY RD BASINS



The Maine Department of Transportation provides this publication for information only. Reliance upon this information is at user risk. It is subject to revision and may be incomplete depending upon changing conditions. The Department assumes no liability if injuries or damages result from this information. This map is not intended to support emergency dispatch.

0.15 Miles
1 inch = 0.11 miles

Date: 6/4/2025
Time: 12:16:49 PM

LEGEND

Guardrail

Not Route XY

Route XY

Drainage Outlets

Culverts - Large

Catch Basins

Network Type

On System

Off System

Bridges - All

Bridge Status

In-Service

Closed

Proposed