



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

March 1, 2018
Subject: Culvert Replacement
State WIN: 023802.00
Location: **Damariscotta**
Amendment No. 2

Dear Sir/Ms.:

The following questions has been received:

Question: If paving plants are not open during the April 16th to April 20th timeframe, would it be acceptable to use temporary pavement or cold patch on the trench and return to prep and pave entire trench when the paving plants open?

Response: That would be an acceptable proposal. Temporary pavement would not be paid for separately, but would be considered incidental to the culvert pipe. All other requirements of the Contract shall be met, particularly the specified Contract Completion date of May 4, 2018 (Amendment 1). The details of such a proposal shall be addressed in the required Contract Modification if the detour route is utilized.

Question: Can the Contractor choose to use Sanitite pipe instead of RCP?

Response: No, an RCP is required.

Consider these changes and information prior to submitting your bid on **March 7, 2018**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER