



STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

Janet T. Mills  
GOVERNOR

Bruce A. Van Note  
COMMISSIONER

March 28, 2022  
Subject: HMA Overlay with Drainage and  
Safety Improvements  
State WIN: 024133.00  
Location: **Newport, Palmyra, and  
Pittsfield**  
**Amendment No. 2**

Dear Sir/Ms.:

The following question has been received:

**Question:** Page 220 states reset 54" RCP left and replace 54" x 24" CMP with RCP. How will this item be paid?

Is a detail available that shows placing RCP on the end of the 36" steel pipe on Route 2?

**Response:** The 54-inch pipe (XC 188372) work referenced on page 220 and permitted will not be completed as part of this project and will be done at a later date.

The 36-inch RCP (XC188373) listed in the Construction Notes at Station 470+75 is intended to replace the 24-inch steel pipe extensions on the right and left. The new 36-inch RCP will connect to existing 36-inch RCP under the roadway.

Consider these changes and information prior to submitting your bid on **March 30, 2022**.

Sincerely,

A handwritten signature in blue ink that reads "George Macdougall".

George M. A. Macdougall P.E.  
Contracts & Specifications Engineer