



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

October 18, 2022
Subject: Whitney Brook Bridge
Replacement
State WIN: 024783.01
Location: Bridgewater
Amendment No. 1

Dear Sir/Ms.:

The following questions have been received:

Question: Can you please confirm the required finish for reinforcing in the NEXT beams?

Response: Plain reinforcing steel shall be used for reinforcing in the NEXT beams.

Consider these changes and information prior to submitting your bid on **October 26, 2022**.

Sincerely,

Kevin Hanlon for

George M. A. Macdougall P.E.
Contracts & Specifications Engineer