STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Dale F. Doughty
ACTING COMMISSIONER

October 21, 2025
Subject: Intersection Safety Improvements & Highway Reconstruction
WIN: 025273.00 & 025751.00
Location: **Augusta**
Amendment No. 3

Dear Sir/Ms.:

The following questions have been received:

Question: It does not specify what schedule the conduit should be in the plans or specifications. Are we installing SCH 40 or 80?

Response: All Non-Metallic conduit shall be schedule 40 unless otherwise noted on the plans.

Consider these changes and information prior to submitting your bid on **October 22, 2025.**

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer