

STATE OF MAINE DEPARTMENT OF TRANSPORTATION 16 STATE HOUSE STATION AUGUSTA, MAINE 04333-0016

Bruce A. Van Note

October 2, 2024

Subject: Highway Reconstruction

Location: Nobleboro State WIN: 025361.00 **Amendment No. 1**

Dear Sir/Ms.:

The following questions have been received:

Question: Excavation is incidental, but there isn't any cross sections. There are cut lines shown on the plan for a few ditchlines, and there will be some boxcutting. Is the contractor to just assume a quantity for this work?

Response: Yes, this is primarily a fill project, there will be some limited excavation including box cutting and ditch work, the contractor should assume a quantity for this incidental work.

Question: Can the contractor get the earthwork done this fall and base pave, then surface pave in the Spring?

Response: Yes

Consider these changes and information prior to submitting your bid on October 9, 2024.

Sincerely,

George M. A. Macdougall P.E. Contracts & Specifications Engineer

Geor Washingoll