



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Dale F. Doughty
COMMISSIONER

March 9, 2026
Subject: Large Culvert Replacement
WIN: 025521.00
Location: **Drew Plantation**
Amendment No. 1

Dear Sir/Ms.:

The following questions have been received:

Question: Please advise if Reinforced Concrete Pipe (RCP) is an acceptable alternate to the 84" CMP specified on the project.

Response: A reinforced concrete pipe (RCP) is an acceptable alternative. If the contractor selects this option, 2 sets of pipe ties (603.55) will need to be installed on each end of the culvert. This will be considered incidental to the pipe and no additional payment will be made. A proposal will need to be submitted after award detailing all specifics.

Consider these changes and information prior to submitting your bid on **March 25, 2026.**

Sincerely,

A handwritten signature in blue ink that reads 'George Macdougall'.

George M. A. Macdougall P.E.
Contracts & Specifications Engineer