



Janet T. Mills
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Dale F. Doughty
ACTING COMMISSIONER

January 30, 2026
Subject: St. Mary's Bridge
Replacement
WIN: 026083.300
Location: Van Buren
Amendment No. 2

Dear Sir/Ms.:

The following questions have been received:

Question: What type of reinforcing (rebar) is specified in the NEXT Beams (black, low chromium, etc...)?

Response: The reinforcing in the NEXT Beams shall be plain bar meeting the requirements of ASTM A615, Grade 60 (black).

Consider these changes and information prior to submitting your bid on February 4, 2026.

Sincerely,

A handwritten signature in blue ink that reads 'George Macdougall'.

George M. A. Macdougall P.E.
Contracts & Specifications Engineer