



Janet T. Mills
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Dale F. Doughty
ACTING COMMISSIONER

December 12, 2025
Subject: Lewis Bridge Replacement
WIN: 026160.00
Location: **Bowdoin**
Amendment No. 1

Dear Sir/Ms.:

The following questions have been received:

Question: Can someone review the quantities of the 606 items? Item 606.743 "Guardrail - Single Rail Culvert Mounted" has an estimated quantity of 113 linear feet yet the span of the Box Culvert is only 22 linear feet.

Response: On Sheet 23, Culvert Mounted Guardrail Details, the detail in the upper lefthand corner titled "Post Spacing for Culvert Mounted Guardrail" indicates the Limits of Payment of Culvert-Mounted Guardrail. The quantity for Pay Item No. 606.743, Guardrail – Single Rail Culvert Mounted, is based on the Limits of Payment of Culvert-Mounted Guardrail.

Consider these changes and information prior to submitting your bid on **January 7, 2026.**

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer