



STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

Janet T. Mills  
GOVERNOR

Bruce A. Van Note  
COMMISSIONER

September 15, 2020  
Subject: Salt Storage Building  
State WIN: 026231.00  
Location: **Randolph**  
**Amendment No. 4**

Dear Sir/Ms.:

The following question has been received:

**Question:** Spec General Notes shows:

3. The Department of Transportation will be responsible for paving in the areas where the pavement was removed for new construction, but the contractor will be responsible for finish grading and compaction intended for new pavement.

Which agrees with note on page 2:

- 1.) MaineDOT will pave exterior area of Salt Shed disturbed during excavation and construction and finish grade outside of building.

But cut C / 11 shows pavement by Contractor inside and outside of the building.  
Please confirm locations where pavement is to be carried by the Contractor.

**Response:** The Contractor will not be responsible for any pavement inside or outside the building. The Contractor will be responsible to fill areas with gravel, proper grades and compaction for MaineDOT to pave inside and around the outside of the building after completion of project.

Consider these changes and information prior to submitting your bid on **September 16, 2020**.

Sincerely,

*Kevin Hanlon for*

George M. A. Macdougall P.E.  
Contracts & Specifications Engineer