



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

July 7, 2020
Subject: Cold Storage Building
State WINs: 026319.00
Location: **Kingfield**
Amendment No. 1

Dear Sir/Ms.:

The following question has been received:

Question: Trying to complete an estimate for the MDOT in Kingfield. I don't see a pitch or elevations. Is this a two sided or mono roof?

Response: The roof of this building is to be a two -sided truss building with a 5/12 pitch minimum

Consider these changes and information prior to submitting your bid on **July 15, 2020**.

Sincerely,

A handwritten signature in blue ink that reads 'George Macdougall'.

George M. A. Macdougall P.E.
Contracts & Specifications Engineer