



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

April 26, 2023
Subject: Pavement Milling & HMA Overlay
State WIN: 026490.00 & 026626.10
Location: **Ashland, Portage Lake &
Nashville**
Amendment No. 1

Dear Sir/Ms.:

The following questions have been received:

Question: Please advise if reinforced Concrete Pipe (RCP) is an acceptable alternate to the CSP specified in section 0210 and 0220 of the tender form (48" & 60")

Response: RCP is an acceptable alternative as it meets the requirement of the Option III specification.

Consider these changes and information prior to submitting your bid on **May 10, 2023**.

Sincerely,

A handwritten signature in blue ink that reads 'George Macdougall'.

George M. A. Macdougall P.E.
Contracts & Specifications Engineer