



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

June 21, 2023
Subject: Shim & Overlay
State WIN: 026690.00
Location: **South Portland**
Amendment No. 1

Dear Sir/Ms.:

The following questions have been received:

Question: Please clarify the areas that are to receive shim pavement?

Response: Locations where more than 3" of material will be placed will require shim. MaineDOT expects such locations to be minimal.

Consider these changes and information prior to submitting your bid on **July 12, 2023**.

Sincerely,

A handwritten signature in blue ink that reads "George Macdougall".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer