



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

June 18, 2020
Subject: Culvert Replacement
State WIN: 026903.00
Location: **Hope**
Amendment No. 1

Dear Sir/Ms.:

The following question has been received:

Question: We are inquiring if the 66 INCH SPAN 51 INCH RISE PIPE ARCH OPTION III is required to have any special interior or exterior coating, or is it just standard Aluminum galvanized?

Response: Polymer-Precoated Galvanized Corrugated Steel Pipe. Aluminum is not allowed due to minimal cover.

Consider these changes and information prior to submitting your bid on **June 24, 2020**.

Sincerely,

A handwritten signature in black ink that reads 'George M. A. Macdougall'.

George M. A. Macdougall P.E.
Contracts & Specifications Engineer