



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

June 3, 2025
Subject: Bridge Rehabilitation
WIN: 026962.10
Location: **Bass Harbor**
Amendment No. 2

Dear Sir/Ms.:

The following questions have been received:

Question: It seems there would need to be access to the electrical components in the truss. Would it make sense to build it as a walking ramp with handrails, with access to the electrical components?

Response: The cable truss only supports conduit and wiring. No other equipment requiring access is supported by the cable truss and a walkway with railings is not required.

Consider these changes and information prior to submitting your bid on **June 11, 2025**.

Sincerely,

A handwritten signature in blue ink, reading 'George M. A. Macdougall'.

George M. A. Macdougall P.E.
Contracts & Specifications Engineer