



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

September 10, 2020
Subject: Maintenance Buildings
Roof Replacement
State WINs: 026997.00 & 026999.00
Location: **Dixfield**
Amendment No. 1

Dear Sir/Ms.:

The following questions have been received:

Question: Just confirming the roof material that will be used to replace the Dixfield Maintenance buildings. Will they be replaced using rubber membrane roofing?

Response: The Roofs will be replaced using EPDM materials.

Question: Is there any information on the square footage of the roofs for both buildings that need roof replacements on the project referenced above?

Response: The roof for Building #21451 is 76 feet x 112 feet, or 8,512 Square Feet; and the roof for Building #35770 is 75 feet x 62 feet, or 4,650 Square Feet.

Question: The two buildings included in the project are labeled #21451 and #35770. When I attended the prebid it didn't occur to me to ask the building numbers. One is substantially larger than the other, could you please distinguish which is which?

Response: See previous response.

Consider these changes and information prior to submitting your bid on **September 16, 2020**.

Sincerely,

A handwritten signature in blue ink that reads "George Macdougall".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer