



STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

Janet T. Mills  
GOVERNOR

Bruce A. Van Note  
COMMISSIONER

May 28, 2025  
Subject: Large Culvert Replacement  
WIN: 027136.00  
Location: **Gardiner**  
**Amendment No. 1**

Dear Sir/Ms.:

The following questions have been received:

**Question:** The existing ground elevations are listed on some drawings but not others (for instance C-001). Drawing C-010 has elevations but the critical elevations for excavation are absent... Would CAD be made available or perhaps a existing conditions drawings with labels?

**Response:** Drawing C1 was provided to MaineDOT by Wright-Pierce on behalf of the Gardiner Water District. MaineDOT shared your request for information with the Wright-Pierce Engineer of Record who offered the following reply:

Due to the way the water main plans were created, overlaying over the MDOT plans, the CAD plans would not be useful. The water main is set at 5' of cover, and a profile is provided in the plans.

Consider these changes and information prior to submitting your bid on **June 11, 2025**.

Sincerely,

George M. A. Macdougall P.E.  
Contracts & Specifications Engineer