



STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

Janet T. Mills  
GOVERNOR

Bruce A. Van Note  
COMMISSIONER

June 18, 2024  
Subject: Cathance River Bridge Substructure  
Rehabilitation  
State WIN: 027494.00  
Location: Topsham  
**Amendment No. 1**

Dear Sir/Ms.:

The following questions have been received:

**Question:** Will shapes other than round be acceptable as long as they have 2" of concrete cover for the pile jackets?

**Response:** If Alternative 1 is selected, non-round pile wraps may be submitted for approval. Proposed pile wraps shall have a minimum theoretical concrete cover of 3" and the entire space between the flanges shall be filled with concrete.

Consider these changes and information prior to submitting your bid on **June 26, 2024**.

Sincerely,

George M. A. Macdougall P.E.  
Contracts & Specifications Engineer