



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Dale F. Doughty
COMMISSIONER

July 14, 2026
Subject: Large Culvert Replacements
WIN:028150.00, 028152.00
Location: Sebago
Amendment No. 2

Dear Sir/Ms.:

The following questions have been received:

Question: On Win # 028152.00 will a skid steer mounted mill head be acceptable for the 15' step joint?

Response: The Department may consider the use of a smaller mill or skid steer trimmer head to complete the milling provided that the successful bidder place an HMA shim surface over the milled areas at no additional costs to the Department.

Consider these changes and information prior to submitting your bid on **July 22, 2026**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer