



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

March 14, 2024
Subject: Supply and Installation of Stand by
Generators
State WIN: 028911.00
Location: **Region 5**
Amendment No. 1

Dear Sir/Ms.:

Please make the following changes to the Bid Documents:

In the Bid Book:

On page 46, “**SPECIAL PROVISIONS, STANDBY GENERATORS**”, in the section “**locations and Specifications**”, the paragraph which begins with Location: Fort Fairfield—86 High Street (Rte. 161) Fort Fairfield, Maine 04742. **CHANGE** “Main Panel Breaker Rated Amps - 200 amp, 10 KA, The generator shall be supplied with a 200 amp service entrance rated fully automatic transfer switch to switch to transfer whole panel.” **TO READ:** Main Panel Breaker Rated Amps - 400 amp 10 KA, The generator shall be supplied with a 400 amp service entrance rated fully automatic transfer switch to transfer the whole panel.

Make this change in pen and ink.

The following questions have been received:

Question: Who is responsible for supplying diesel fuel for generators?

Response: The Department will supply diesel fuel for the initial startup and testing.

Question: The Documents call out a 200-amp automatic transfer switch at the Fort Fairfield site. The service entrance has been upgraded to a 400 amp single phase 120/240 recently. Are we to assume the ATS and wiring will be upgraded as well?

Response: Yes, it will now require a 400 amp transfer switch.

Consider these changes and information prior to submitting your bid on **March 27, 2024**.

Sincerely,



George M. A. Macdougall P.E.
Contracts & Specifications Engineer