



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

July 27, 2023
Subject: Wetland Culvert Replacement
State WIN: 029085.00
Location: **Alna**
Amendment No. 1

Dear Sir/Ms.:

The following questions have been received:

Question: Please advise if reinforced concrete pipe (RCP) is acceptable for this project.

Response: The Department will supply a Poly Coated CMP or a gray plastic pipe. Refer to Construction Notes on page 31 of the Bid Book paragraph 1 "Proposed: Replace one of the twin pipes with a 60" x 60' Option III supplied by the Department and leave the other in place." Also, in the Construction Notes refer to bullet 9 "The Department will supply the pipe and will deliver onsite."

Question: Please advise if RCP is allowed will 64' length be acceptable (RCP in 60" size comes in 8' sections)

Response: N/A

Consider these changes and information prior to submitting your bid on **August 16, 2023**.

Sincerely,

A handwritten signature in blue ink that reads "George Macdougall".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer