



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

January 22, 2025
Subject: Basement Drainage System
WIN: 030353.00
Location: Scarborough Region 1
Headquarters

Dear Sir.

See attached Attendance sheet for mandatory Pre-bid meeting.

The following questions were received at the pre-bid meeting:

Question: Will equipment and items in storage area be moved prior to construction?

Response: Yes, refer to page 10 of the Bid Book.

Question: Can Sump be powered off existing circuit?

Response: Yes, any electrical work will be completed by the Department refer to page 10 in the Bid Book.

Question: Will work need to take place after hours?

Response: No, all work will be completed during the following times Monday thru Friday 6:30 AM- 4:30PM except for Holidays. Refer to page 11 of the Bid Book.

Question: Existing sump has 2 pumps for redundancy. Are we only to add a single sump at the new location?

Response: Refer to page 9 of the Bid Book: Supply & install TripleSafe pump system with twin liner, 1/3 hp cast iron primary AC pump, 1/2 hp cast iron AC back-up pump, and UltraSump battery back-up pumping system with charging/control box with alarm, and 120 amp sealed maintenance free battery. To include 3 CleanPump stands, airtight lid with airtight floor drain, and WaterWatch alarm system.

Consider these changes and information prior to submitting your bid on **January 29, 2025.**

Sincerely,

A handwritten signature in blue ink that reads 'George Macdougall'.

George M. A. Macdougall P.E.
Contracts & Specifications Engineer



Town SCARBOROUGH

WIN	030353.00	Pre-Bid Meeting
-----	-----------	-----------------

[illegible]