



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Dale F. Doughty
COMMISSIONER

April 17, 2026
Subject: Add Shoulder
Aggregate to Existing
Shoulders
WIN:031148.00
Location: Region 3
Amendment No. 1

Dear Sir/Ms.:

The following questions have been received:

Question: Will any form of compaction be required on the placed gravel?

Response: At a minimum, compaction shall be completed with a plate compactor, however, other methods may be used such as a single or dual drum steel roller provided the edge of pavement is not damaged and must be approved by the project resident prior to compacting.

Consider these changes and information prior to submitting your bid on **May 6, 2026.**

Sincerely,

A handwritten signature in blue ink that reads 'George Macdougall'.

George M. A. Macdougall P.E.
Contracts & Specifications Engineer