



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Dale F. Doughty
COMMISSIONER

May 1, 2026
Subject: Add Shoulder
Aggregate
WIN:031148.00
Location: Region 3
Amendment No. 2

Dear Sir/Ms.:

The following questions have been received:

Question: Does the department have a targeted width and depth of shoulder Aggregate material placement?

Response: Approximately 12 to 16 inches wide but may vary in some areas to align the existing shoulders with the new pavement when compacted.

Consider these changes and information prior to submitting your bid on **May 6, 2026.**

Sincerely,

A handwritten signature in blue ink that reads "George Macdougall".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer