

# Andrew McCullough

## Engineering Consultants

93 Bucksport Road

PO Box 1497

Ellsworth, Maine 04605

Phone: 207-667-6551

Fax: 207-667-7137

e-mail: [mccengr@myfairpoint.net](mailto:mccengr@myfairpoint.net)

---

November 12, 2021

RE: Sea Wall Rehabilitation/ Betsy's Cove Site Improvements/ WIN # 025213.00

Addendum 3

Response to RFI's

1. Attendance at the Bid Opening is not required. Bids may be sent to [mccengr@gmail.com](mailto:mccengr@gmail.com). A paper copy of the bid and bid bond will be required within 72 hours.
2. It will be the Contractors' choice to select the method used for tie-backs.
3. The sheet steel for the tie-back shall be galvanized and shall meet the specifications and surface area of the NZ-26 sheet piling.
4. Item: Removal and Replacement of the Flag Pole- The existing flag pole will not be re-used. A new tapered satin aluminum flag pole with a height of 25 feet, suitable to withstand a wind speed of 137 mph unflagged and 105 mph flagged shall be supplied and installed. Butt Diameter-5 inches, Top Diameter-3 inches. Minimum wall thickness 0.125 inches. The light pole shall be equipped with a disk solar light with led illumination.