



Janet T. Mills
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Bruce A. Van Note
COMMISSIONER

November 18, 2019
Subject: Supply & Delivery of Precast
Concrete Box Culvert
State WIN: PH021831.00P
Location: **Stockton Springs**
Amendment No. 1

Dear Sir/Ms.:

Please make the following changes to the Bid Documents:

In the Bid Book:

ADD the attached "SPECIAL PROVISION 102.7.3 – ACKNOWLEDGEMENT OF BID AMENDMENTS" form, 1 page, dated April 14, 2011.

The following questions have been received:

Question: What is the depth of soil cover for this culvert?

Response: The depth of cover is approximately 18 feet.

Question: What cover depth (over the box culvert) should we be designing for?

Response: See previous response.

Consider these changes and information prior to submitting your bid on **November 27, 2019**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer

SPECIAL PROVISION 102.7.3
ACKNOWLEDGMENT OF BID AMENDMENTS

With this form, the Bidder acknowledges its responsibility to check for all Amendments to the Bid Package. For each Project under Advertisement, Amendments are located at <http://www.maine.gov/mdot/contractors/> . It is the responsibility of the Bidder to determine if there are Amendments to the Project, to download them, to incorporate them into their Bid Package, and to reference the Amendment number and the date on the form below. The Maine DOT will not post Bid Amendments any later than noon the day before Bid opening without individually notifying all the planholders.

Amendment Number	Date

The Contractor, for itself, its successors and assigns, hereby acknowledges that it has received all of the above referenced Amendments to the Bid Package.

CONTRACTOR

Date

Signature of authorized representative

(Name and Title Printed)