



Janet T. Mills
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Bruce A. Van Note
COMMISSIONER

March 28, 2019
Subject: Expansion Joint Armor
Fabrication
State WIN: PH023682.00, PH025402.00,
PH025446.00 & PH025440.00
Location: **Harrington, Dover-Foxcroft, T2
R8 NWP & Eagle Lake**
Amendment No. 1

Dear Sir/Ms.:

The following question has been received:

Question: Are shop drawings required for the joint armor?

Response: To help facilitate the fabrication and delivery of the joint armor the Department will not require shop drawings for this project. The design drawings may be used for fabrication, however there will be a mandatory pre-fabrication meeting to discuss project specifics prior to the start of fabrication.

Consider these changes and information prior to submitting your bid on **April 3, 2019**.

Sincerely,

for 

George M. A. Macdougall P.E.
Contracts & Specifications Engineer