



STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

Janet T. Mills  
GOVERNOR

Bruce A. Van Note  
COMMISSIONER

November 14, 2022  
Subject: Precast Concrete  
Box Culvert  
State WIN: PH025397.00P  
Location: **Arundel**  
**Amendment No. 1**

Dear Sir/Ms.:

The following questions have been received:

**Question:** Can you please confirm the type / finish on the rebar used for the reinforcing of the box culvert (i.e. Black, Epoxy Coated, HDG, Low Carbon Chromium, etc...)?

**Response:** Reinforcing bars shall meet the requirements of ASTM A615 and shall be black. Welded wire fabric shall meet the requirements of AASHTO M 336 and shall be black.

Consider these changes and information prior to submitting your bid on **November 23, 2022**.

Sincerely,

A handwritten signature in blue ink that reads 'George Macdougall'.

George M. A. Macdougall P.E.  
Contracts & Specifications Engineer