



STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

Janet T. Mills  
GOVERNOR

Bruce A. Van Note  
COMMISSIONER

December 14, 2022  
Subject: Supply and Installation of  
Standby Generator  
State WIN:PH028037.00  
Location: Crystal, Houlton,  
Medway, Oakfield and Springfield  
**Amendment No. 4**

Dear Sir/Ms.:

The following questions have been received:

**Question:** Who supplies the propane for the state installed tanks

**Response:** MaineDOT uses several different vendors to include Daigle Oil, Northeast Propane, Dead River, and F.W Web.

**Question:** the specs mention the state installing the propane tanks, but we don't know how far from the generators these tanks will be. If we are to install the gas piping should we be just allowing an average distance between the tank and gen?

**Response:** Each tank will be located a minimum of 10' and a maximum of approximately 25' from each generator location.

Consider these changes and information prior to submitting your bid on **December 21, 2022.**

Sincerely,

A handwritten signature in blue ink that reads "George Macdougall".

George M. A. Macdougall P.E.  
Contracts & Specifications Engineer