



Janet T. Mills
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Bruce A. Van Note
COMMISSIONER

June 24, 2019
Subject: HVAC Preventative Maintenance
& Repair Work
State WIN: PH20190605AC5
Location: **Region 5**
Amendment No. 1

Dear Sir/Ms.:

The following question has been received:

Question: Could you please clarify the instructions concerning the second filter change in January. Would this be air filters only in warm air units?

Response: These are Hot Air Furnaces and the filters are to be changed annually between July 1 and September 30, during the regularly scheduled preventative maintenance work, and again in January or February.

Consider these changes and information prior to submitting your bid on **June 26, 2019**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer