



STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

Janet T. Mills  
GOVERNOR

Bruce A. Van Note  
COMMISSIONER

February 8, 2022  
Subject: HVAC, Ductwork & Ventilation  
Cleaning Services  
State WIN: PH20220126BHV  
Location: **Bangor**  
**Amendment No. 3**

Dear Sir/Ms.:

The following questions have been received:

**Question:** Are exhaust systems to be cleaned?

**Response:** Yes.

**Question:** If exhaust systems are to be cleaned, is there access in the duct to perform the cleaning?

**Response:** It is unknown if there is adequate access in the ducts to perform the cleaning.

**Question:** Are exhaust ducts stainless steel or galvanized sheet metal?

**Response:** The exposed ducts appears to be galvanized sheet metal/ pipe, except in the asphalt lab, there are short runs of stainless, 4- 4inch flex duct into a blower exhaust system, approximately 6 foot each run.

**Question:** Are there hazardous materials in the ductwork to be cleaned, and if so, what are they?

**Response:** There are no known hazardous materials in the ductwork.

Consider these changes and information prior to submitting your bid on **February 9, 2022**.

Sincerely,

A handwritten signature in blue ink that reads "George Macdougall".

George M. A. Macdougall P.E.  
Contracts & Specifications Engineer