



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Janet T. Mills
GOVERNOR

Bruce A. Van Note
COMMISSIONER

February 6, 2024
Subject: HVAC Preventative
Maintenance & Repair Work
MaineDOT Headquarters
State WIN: PH20240117HQHV
Location: **Augusta**
Amendment No. 2

Dear Sir/Ms:

Please make the following changes to the Bid Documents:

The following question has been received:

Question: Are the box filters (Hepa) part of the annual maint? These only have to be done every 3 years?

Response: The Hepa filters are to be replaced every three years and supervision, labor, equipment, materials, parts, supplies and all other incidentals necessary to perform the Work are included in the bid price.

Consider this change (these changes) and information prior to submitting your bid on **February 7, 2024.**

Sincerely,

A handwritten signature in blue ink that reads "George Macdougall".

George M. A. Macdougall P.E.
Contracts & Specifications Engineer