## Gause, John P

From:

Gause, John P

Sent:

Thursday, February 05, 2009 10:41 AM

To:

Davis, Fran; Ryan, Patricia

Subject: RE: question regarding Lula lift

Fran,

If what they are doing is an "alteration," they can install a "LuLa lift" that meets all of the requirements of ADAAG § 4.10 other than dimensions, so long as "usability can be demonstrated." See ADAAG § 4.16(3)(c)(iii). "Usability" would require that it meets the minimum clear floor spaces shown in ADAAG Figure 4. See id.

If the renovation affects "at least 80% of the space of the internal structure of facilities," 5 M.R.S.A. § 4594-F(1)(H), however, it would be "new construction," and they would need to install an elevator that fully complied (including dimensions) with ADAAG § 4.10.

John

From: Davis, Fran

Sent: Tuesday, January 27, 2009 3:26 PM

To: Gause, John P; Ryan, Patricia

Subject: FW: question regarding Lula lift

I haven't had a question about installing a Lula in eons. I am unclear about the attached drawings since it looks like the space is already there for a regular elevator and not a Lula. But, aside from that query, I think that we don't give opinions on the type of access (unless it's a chair glide) but only comment on whether access is required. What is your opinion? Fran

Francia Davis Compliance Officer Maine Human Rights Commission 51 State House Station Augusta, ME 04333 207/624-6050

----Original Message----

From:

Sent: Tuesday, January 27, 2009 2:28 PM

To: Davis, Fran

Cc:

Subject: question regarding Lula lift

Dear Fran,

Rich McCarthy directed my question to your office for clarification. I am working on a library renovation and addition in Lovell, Maine and the Owner is very interested in using a Lula lift instead of an elevator. The existing library currently does not have a lift or elevator and we are providing one in

the new construction portion of the building (see attached PDF drawings). Is it acceptable to use a Lula in place of the elevator as shown for this application?

