

Assessment for: Bethel Water District, ME0090160

Location: Bethel, Maine

Date: August 13, 2009

Summary of the Data used in our Assessment

Public Water Supply Information

Well type: Gravel Pit

Well identification number: 90160202

Well description: Gravel Pit Well 36 ft

Overburden thickness (feet): N/A

Wellhead protection radius around the well: 2500 ft

Reported distance of land control around the well: 240 ft

Wellhead Protection Ordinance in effect: No

Risk Based on Well Type and Site Geology

Ranking:

Well type: Gravel Pit

Overburden thickness (feet): N/A

Existing risk of contamination based on well type & site geology:

Moderate risk

Existing Risk of Acute Contamination

Ranking:

Positive coliform test: No

Nitrate test greater than 5 ppm: No

Septic system within 300 feet of the well: No

Existing risk of acute contamination:

Low risk

Future Risk of Acute Contamination

Future Ranking:

No legal land control or control status is unknown or

legal control is less than a 150-foot radius around the well: No

Legal control of at least a 150-foot radius of property around the well: Yes

Legal control of at least a 300-foot radius of property around the well: No

Future risk of acute contamination:

Moderate risk

Existing Risk of Chronic Contamination

Ranking:

Detection of Chronic Chemical Contaminant: No

Name(s) of Chronic Chemical Contaminant(s) Detected: N/A

Total No. Potential Sources of Contamination within WHPA: 1

Distance to nearest "Significant Potential Source of Contamination": 240 ft

Name of nearest "Significant Potential Source of Contamination": residential property

Existing risk of chronic contamination:

Low risk

Future Risk of Chronic Contamination - Land Ownership / Control

Legal control of Entire Wellhead Protection Area: No

Legal control of 2500 Phase II/V Waiver Radius: No

Future risk of chronic contamination:

High risk