

Assessment for: Hancock Lumber -bethel, Inc., ID ME0094369

Location: Bethel, Maine

Date: April 15, 2003

Summary of the Data used in our Assessment

Public Water Supply Information

Well type: Gravel well

Well identification number: 94369202

Well description: Gravel Packed Well 52' #3

Overburden thickness (feet): 52

Wellhead protection radius around the well: 300

Reported distance of land control around the well: No data reported

Risk Based on Well Type and Site Geology

Well type: Gravel well

Well identification number: 94369202

Overburden thickness (feet): 52

*Existing risk of contamination
based on well type & site geology:*

Moderate risk

Existing Risk of Acute Contamination

Well identification number: 94369202

Positive coliform test: Yes

Nitrate test greater than 5 ppm: No

Septic system within 300 feet of the well: Yes

Existing risk of acute contamination:

High risk

Future Risk of Acute Contamination

Well identification number: 94369202

No legal land control or control status is unknown or

legal control is less than a 150-foot radius around the well: Yes

Legal control of at least a 150-foot radius of property around the well: No

Legal control of at least a 300-foot radius of property around the well: No

Future risk of acute contamination:

High risk

Existing Risk of Chronic Contamination

Well identification number: 94369202

Detection of Chronic Chemical Contaminant: Yes

Name(s) of Chronic Chemical Contaminant(s) Detected: Chromium

Total No. Potential Sources of Contamination within WHPA: 7

Distance to nearest "Significant Potential Source of Contamination": 300 (feet)

Name of nearest "Significant Potential Source of Contamination": Small engine repair shop

Existing risk of chronic contamination:

High risk

Future Risk of Chronic Contamination - Land Ownership / Control

Legal control of Entire Wellhead Protection Area: No

Legal control of 2500 Phase II/V Waiver Radius: No

Future risk of chronic contamination:

High risk