

Assessment for: Camp Newfound, ID ME0000798  
Location: Harrison, Maine  
Date: May 8, 2003

### **Summary of the Data used in our Assessment**

Well type: Bedrock Well  
Well identification number: 798105  
Well description: Drilled Well 188' (camp's #2)  
Overburden thickness (feet): Unknown  
Positive bacteria test result(s): No  
Nitrate test result(s) greater than 5 ppm: No  
Septic system(s) within 300 feet of the well: Yes  
Animal feedlots/manure piles(s) within 300 feet of the well: No

### **Risk Based on Well Type and Site Geology**

*Ranking:*

Well type: Bedrock Well  
Overburden thickness (feet): Unknown

*Existing risk of contamination  
based on well type & site geology:*

**Moderate risk**

### **Existing Risk of Acute Contamination**

*Ranking:*

Positive coliform test(s): No  
Nitrate test(s) greater than 5 ppm: No  
Septic system(s) within 300 feet of the well: Yes  
Animal feedlot(s)/manure pile(s) within 300 feet of the well: No

*Existing risk of acute contamination:*

**Moderate risk**

### **Future Risk for Acute Contamination**

*Ranking:*

Status of land control: The source proprietor owns or controls all the land within 300 feet of this water supply source.

*Future risk of acute contamination:*

**Low risk**