

Assessment for: Isle View Motel & Cottages; ID ME0003529

Location: Trenton, Maine

Date: June 13, 2012

Summary of the Data used in our Assessment

Well type: Bedrock well

Well identification number: 3529101

Well description: Bedrock well; depth is 260 ft

Overburden thickness (feet): 0 ft

Positive bacteria test result(s): Yes

Nitrate test result(s) greater than 5 ppm: No

Septic system(s) within 300 feet of the well: No

Animal feedlots/manure piles(s) within 300 feet of the well: No

Risk Based on Well Type and Site Geology

Ranking:

Well type: Bedrock well

Overburden thickness (feet): 0 ft

*Existing risk of contamination
based on well type & site geology:*

Moderate risk

Existing Risk of Acute Contamination

Ranking:

Positive coliform test(s): Yes

Nitrate test(s) greater than 5 ppm: No

Septic system(s) within 300 feet of the well: No

Animal feedlot(s)/manure pile(s) within 300 feet of the well: No

Existing risk of acute contamination:

High Risk

Future Risk for Acute Contamination

Ranking:

Status of land control: The owner owns and/or controls app 85 ft of the WHPR of 300 ft

Future risk of acute contamination:

High risk