

Assessment for: Trenton Health Center; ID ME0094893

Location: Trenton, Maine

Date: July 13, 2010

### **Summary of the Data used in our Assessment**

Well type: Bedrock well

Well identification number: 94893101

Well description: Bedrock well; 400 ft deep

Overburden thickness (feet): 40

Positive bacteria test result(s): No

Nitrate test result(s) greater than 5 ppm: No

Septic system(s) within 300 feet of the well: No

Animal feedlots/manure piles(s) within 300 feet of the well: No

### **Risk Based on Well Type and Site Geology**

*Ranking:*

Well type: Bedrock well

Overburden thickness (feet): 40

*Existing risk of contamination  
based on well type & site geology:*

*Low risk*

### **Existing Risk of Acute Contamination**

*Ranking:*

Positive coliform test(s): No

Nitrate test(s) greater than 5 ppm: No

Septic system(s) within 300 feet of the well: No

Animal feedlot(s)/manure pile(s) within 300 feet of the well: No

*Existing risk of acute contamination:*

*Low risk*

### **Future Risk for Acute Contamination**

*Ranking:*

Status of land control: The owner does not own and control the land within the Well Head Protection Radius of 300 ft.

*Future risk of acute contamination:*

*High risk*