

Assessment for: Waldoboro Water Dept, ME0091560
Location: Waldoboro, Maine
Date: August 19, 2009

Summary of the Data used in our Assessment

Public Water Supply Information

Well type: Bedrock well
Well identification number: 91560102
Well description: Bedrock well drilled 200 ft
Overburden thickness (feet): 50 ft
Wellhead protection radius around the well: 2000 ft
Reported distance of land control around the well: 300 ft
Wellhead Protection Ordinance in effect: Yes

Risk Based on Well Type and Site Geology

Ranking:

Well type: Bedrock
Overburden thickness (feet): 50 ft

Existing risk of contamination based on well type & site geology:

Low risk

Existing Risk of Acute Contamination

Ranking:

Positive coliform test: No
Nitrate test greater than 5 ppm: No
Septic system within 300 feet of the well: No

Existing risk of acute contamination:

Low risk

Future Risk of Acute Contamination

Future Ranking:

No legal land control or control status is unknown or
legal control is less than a 150-foot radius around the well: No
Legal control of at least a 150-foot radius of property around the well: Yes
Legal control of at least a 300-foot radius of property around the well: Yes

Future risk of acute contamination:

Low risk

Existing Risk of Chronic Contamination

Ranking:

Detection of Chronic Chemical Contaminant: No
Name(s) of Chronic Chemical Contaminant(s) Detected: None
Total No. Potential Sources of Contamination within WHPA: 2
Distance to nearest "Significant Potential Source of Contamination": 300 ft
Name of nearest "Significant Potential Source of Contamination": Residential property

Existing risk of chronic contamination:

Low risk

Future Risk of Chronic Contamination - Land Ownership / Control

Legal control of Entire Wellhead Protection Area: No
Legal control of 2500 Phase II/V Waiver Radius: No

Future risk of chronic contamination:

High risk