



A Unitil company

March 20, 2026

Nathan Dore
Gas Safety Manager
Maine Public Utilities Commission
18 State House Station
Augusta, ME 04333-0018

RE: February 2026 – Leak & Odor Call Response, Facility Damage Due to Utility Error, and Leak and Odorant Report

Dear Mr. Dore,

This report is in accordance with the Conditions placed on Maine Natural Gas (MNG) in the Stipulation of Docket No. 2007-335.

a. Leak & Odor Call Response:

Attachment 1 is a spreadsheet indicating the leak and odor call response times for the month of February 2026. The list includes calls during both working and non-working hours and includes those that may have involved problems with the customer's equipment and/or alarms. MNG's Emergency Call Center also dispatches our Technicians for Emergency Dig Safe notifications during non-working hours. Those responses are not listed on the attached spreadsheet.

b. Facility Damage Due to Utility Error:

There were not any incidents causing damage to MNG's facilities due to Utility Error in the month of February 2026.

c. Submit a Monthly Leak and Odorant Report:

Attachment 2 is a spreadsheet of Maine Natural Gas' odorant level readings for January 2026. Our Operations and Maintenance Procedures require that odorant be readily detectable at a concentration of 0.50% gas in air.

Below is the current status of leaks on MNG's system:

Leak Type	No. of Leaks as of 02/01/2026	No. of Leaks Found in February 2026	No. of Leaks Repaired in February 2026	# of Leaks Awaiting Repair as of 3/01/2026
Grade 1	0	0	0	0
Grade 2	0	0	0	0
Grade 3	0	0	0	0
Above Ground	0	6	6	0

If you have any questions or require additional information, please do not hesitate to contact me.

Sincerely,



Joseph Gauthier, PE
Principal Gas Engineer

Attachments:

Attachment 1 – February 2026 Emergency Response Summary

Attachment 2 – February 2026 Odorant Level Readings

cc: Joe Renda- Manager, Gas Distribution Operations, Unitil, via email
Katherine Silver- Manager, Gas Compliance, Unitil, via email